HEALTH, SAFETY & RISK MANAGEMENT
Michael O'Rourke
Program Administrator

175 Route 32 North • New Paltz, NY 12561
Telephone: 845-255-1400 • Facsimile: 845-255-3826
Email:morourke@ulsterboces.org

#082-1617

Environmental Hygiene Report

Attn: Maria C. Rice
Superintendent of Schools
New Paltz Central School District
196 Main Street, New Paltz, NY 12561
Prepared by: Michael O'Rourke, RPIH – No. 0500399

Location(s)	Duzine Elementary & Lenape Elementary
Project No.	082-1617
Site Visit(s)	September 15, 21, 28 & 29, 2016
Report Date	November 3, 2016
Investigator(s)	Michael O'Rourke Brian Colandrea

Ulster County BOCES *Health, Safety &Risk Management* does not assert that all potential health or safety hazards at this site were evaluated during this survey. This survey is strictly limited to that which is identified in the Project Scope of the report.

TABLE OF CONTENTS

Executive Summary	1
Project Scope	1
Materials & Methods	1
Results Summary	2
Discussion	3
Comments & Recommendations	3
References	4
Appendix A	Laboratory Report(s)
Appendix B	Caution Signage

Author's Note: Parenthetical numerals at the end of a sentence reference the work with the corresponding notation in the **References** section. ***Please read this report in its entirety, including any attached appendices, to fully understand this investigation.***

Executive Summary

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets in the two elementary schools in the New Paltz Central School District on September 15, 21, 28 & 29, 2016. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 172 such water outlets in the two elementary schools. There were 10 other locations sampled at Duzine Elementary using the DOH's protocol prior to the enactment of the law. Of these 182 locations, 23 exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, these outlets must be taken out of service until remediation and re-testing indicate that the lead levels are at or below the action level. If a location, like a toilet room sink, is needed for hygiene purposes signage can be posted (see **Appendix B**) instructing building occupants this water is not intended for drinking purposes. Please note that this is a short-term solution while remediation and re-testing are conducted.

Project Scope

Identify appropriate potable water sampling locations and collect samples from plumbing fixtures in the two elementary school buildings in the New Paltz Central School District for analysis for lead content. Review the data and information and prepare a written report for the New Paltz Central School District.

Materials & Methods

All samples were collected from the type of plumbing fixtures where potable water is commonly drawn using the NYSDOH protocol. First-draw samples for lead were collected after

the water had sat in the pipes for at least eight hours. All samples were collected in 250 ml containers provided by EnviroTest Laboratories in Newburgh, NY. The samples were returned to the laboratory two days after sampling for analysis per the lab's directives. EnviroTest is NYS ELAP-approved (#10142) for potable and non-potable water analysis.

Results Summary

All sample results and other data were reported to the administration of the local educational agency (LEA) via phone, fax, or e-mail as they became available to our department. See Appendix A for full laboratory reports.

Water Samples that Exceeded Action Level

September 15&21, 2016

Duzine Elementary

Sample	Location	Result (ppb)
D30	Room 31 Toilet Room Sink Faucet	140
D37	Room 25 Sink Faucet	24
D41	Room 20 Sink Faucet	18
D43	Room 18 Sink Faucet	16
D45	Room 16 Sink Faucet	34
D47	Room 14 Sink Faucet	22
D66	Room 10 Sink Faucet	16
D68	Room 8 Sink Faucet	17
D70	Room 6 Sink Faucet	16
D71	Room 4 Sink Faucet	17
D73	Room 2 Sink Faucet	29

September 28&29, 2016

Lenape Elementary

Sample	Location	Result (ppb)
L03	Kitchen Center Sink Faucet	53
L05	Kitchen Coffee Pot Sink Faucet	41
L06	Room 115 Sink Faucet	19
L10	Room 118 Sink Faucet	26
L12	Room 121 TR Sink Faucet	16
L30	Room 102 Left Sink Faucet	26
L36	Room 104 Left Sink Faucet	19
L74	Room 209 Sink Faucet	16
L85	Room 216 Far Left Sink Faucet	19

L86	Room 216 Corner Right Sink Faucet	18
L88	Room 216 Left Sink Faucet Under Tarpon	22
L96	Room 219 Sink Faucet	18

Discussion

In order to be used as healthful fluid for human consumption, water must be free from organisms that are capable of causing disease and from minerals and organic substances that could produce adverse physiological effects. ***(1)*** The Safe Dirking Water Act sets maximum contaminant levels (MCLs) for numerous contaminants. These include various inorganic, volatile organic, and synthetic organic compounds. Public water systems are required to do initial and periodic testing of their source water.

Comments & Recommendations

Per the requirements of Subpart 67-4: Lead Testing in School Drinking Water, we sampled water outlets in the two elementary schools in the New Paltz Central School District on September 15, 21, 28 & 29, 2016. Sampling was done early in the morning before most of the building occupants arrived. The regulation defines a water outlet as one that is currently or may potentially be used for cooking or drinking. We identified a total of 172 such water outlets in the two elementary schools. There were 10 other locations sampled at Duzine Elementary using the DOH's protocol prior to the enactment of the law. Of these 182 locations, 23 exceeded the 15 parts per billion (ppb) action level. Per 67-4.4, these outlets must be taken out of service until remediation and re-testing indicate that the lead levels are at or below the action level. If a location, like a toilet room sink, is needed for hygiene purposes signage can be posted (see **Appendix B**) instructing building occupants this water is not intended for drinking purposes. Please note that this is a short-term solution while remediation and re-testing are conducted.

New Paltz Middle School and High School were sampled on October 22 & 29 and we will generate reports when results are available.

References

1. **American Water Works Association:** *Water Quality and Treatment*. New York, NY: McGraw-Hill, 1990

2. **Bailey, R.A. et. al.:** *Chemistry of the Environment*. New York, NY: Academic Press, 1978.

3. **USEPA:** *3Ts for Reducing Lead in Drinking Water in Schools.* Washington, DC: USEPA, 2006.

APPENDIX A

Laboratory Reports

EnviroTest Laboratories Inc.

ANALYTICAL REPORT

Job Number: 420-110751-1

SDG Number: New Paltz CSD Duzine

Job Description: Ulster BOCES

For:
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Attention: Michael O'Rourke

Meredith Ruthven

Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
10/31/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-110751-1
SDG Number: New Paltz CSD Duzine

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-110751-1
SDG Number: New Paltz CSD Duzine

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Sirico, Derek	DS

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-110751-1
SDG Number: New Paltz CSD Duzine

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110751-1	D1, sink in center of kitchen	Drinking Water	09/15/2016 0718	09/23/2016 1215
420-110751-2	D2, sink at back of kitchen	Drinking Water	09/15/2016 0719	09/23/2016 1215
420-110751-3	D3, kitchen toilet room sink	Drinking Water	09/15/2016 0719	09/23/2016 1215
420-110751-4	D4, faculty room sink	Drinking Water	09/15/2016 0721	09/23/2016 1215
420-110751-5	D5, Room 24 sink	Drinking Water	09/15/2016 0723	09/23/2016 1215
420-110751-6	D6, Room 24 water fountain	Drinking Water	09/15/2016 0723	09/23/2016 1215
420-110751-7	D7, Room 24 toilet room sink	Drinking Water	09/15/2016 0724	09/23/2016 1215
420-110751-8	D8, Room 26 sink	Drinking Water	09/15/2016 0727	09/23/2016 1215
420-110751-9	D9, Room 26 water fountain	Drinking Water	09/15/2016 0728	09/23/2016 1215
420-110751-10	D10, Room 26 toilet room sink	Drinking Water	09/15/2016 0729	09/23/2016 1215
420-110751-11	D11, Room 28 sink	Drinking Water	09/15/2016 0703	09/23/2016 1215
420-110751-12	D12, Room 28 toilet room sink	Drinking Water	09/15/2016 0731	09/23/2016 1215
420-110751-13	D13, Room 30 sink	Drinking Water	09/15/2016 0734	09/23/2016 1215
420-110751-14	D14, Room 30 water fountain	Drinking Water	09/15/2016 0734	09/23/2016 1215
420-110751-15	D15, Room 30 toilet room sink	Drinking Water	09/15/2016 0735	09/23/2016 1215
420-110751-16	D16, Room 32 sink	Drinking Water	09/15/2016 0737	09/23/2016 1215
420-110751-17	D17, Room 32 water fountain	Drinking Water	09/15/2016 0738	09/23/2016 1215
420-110751-18	D18, Room 32 toilet room sink	Drinking Water	09/15/2016 0739	09/23/2016 1215
420-110751-19	D19, Women's Fac. Restroom by Rm 32, sink	Drinking Water	09/15/2016 0740	09/23/2016 1215
420-110751-20	D20, Room 34 sink	Drinking Water	09/15/2016 0742	09/23/2016 1215
420-110751-21	D21, Room 34 toilet room sink	Drinking Water	09/15/2016 0742	09/23/2016 1215
420-110751-22	D22, Room 35 sink	Drinking Water	09/15/2016 0744	09/23/2016 1215
420-110751-23	D23, Room 35 water fountain	Drinking Water	09/15/2016 0744	09/23/2016 1215
420-110751-24	D24, Room 35 toilet room sink	Drinking Water	09/15/2016 0746	09/23/2016 1215
420-110751-25	D25, lavatory sink next to Room 35	Drinking Water	09/15/2016 0747	09/23/2016 1215
420-110751-26	D26, Room 33 sink	Drinking Water	09/15/2016 0748	09/23/2016 1215
420-110751-27	D27, Room 33 water fountain	Drinking Water	09/15/2016 0750	09/23/2016 1215
420-110751-28	D28, Room 31 sink	Drinking Water	09/15/2016 0751	09/23/2016 1215
420-110751-29	D29, Room 31 water fountain	Drinking Water	09/15/2016 0752	09/23/2016 1215
420-110751-30	D30, Room 31 toilet room sink	Drinking Water	09/15/2016 0754	09/23/2016 1215
420-110751-31	D31, Room 29 sink	Drinking Water	09/15/2016 0755	09/23/2016 1215
420-110751-32	D32, Room water fountain	Drinking Water	09/15/2016 0756	09/23/2016 1215

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-110751-1
SDG Number: New Paltz CSD Duzine

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110751-33	D33, Room 29 toilet room sink	Drinking Water	09/15/2016 0756	09/23/2016 1215
420-110751-34	D34, Room 27 sink	Drinking Water	09/15/2016 0758	09/23/2016 1215
420-110751-35	D35, Room 27 water fountain	Drinking Water	09/15/2016 0759	09/23/2016 1215
420-110751-36	D36, Room 27 toilet room sink	Drinking Water	09/15/2016 0759	09/23/2016 1215
420-110751-37	D37, Room 25 sink	Drinking Water	09/15/2016 0800	09/23/2016 1215
420-110751-38	D38, Room 21 sink	Drinking Water	09/21/2016 0717	09/23/2016 1215
420-110751-39	D39, Room 21 water fountain	Drinking Water	09/21/2016 0717	09/23/2016 1215
420-110751-40	D40, Room 19 sink	Drinking Water	09/21/2016 0719	09/23/2016 1215
420-110751-41	D41, Room 20 sink	Drinking Water	09/21/2016 0720	09/23/2016 1215
420-110751-42	D42, Room 17 sink	Drinking Water	09/21/2016 0721	09/23/2016 1215
420-110751-43	D43, Room 18 sink	Drinking Water	09/21/2016 0722	09/23/2016 1215
420-110751-44	D44, Room 15 sink	Drinking Water	09/21/2016 0724	09/23/2016 1215
420-110751-45	D45, Room 16 sink	Drinking Water	09/21/2016 0725	09/23/2016 1215
420-110751-46	D46, Room 13 sink	Drinking Water	09/21/2016 0727	09/23/2016 1215
420-110751-47	D47, Room 14 sink	Drinking Water	09/21/2016 0729	09/23/2016 1215
420-110751-48	D48, Girl's room by Library, left sink	Drinking Water	09/21/2016 0730	09/23/2016 1215
420-110751-49	D49, Girl's room by Library, center sink	Drinking Water	09/21/2016 0731	09/23/2016 1215
420-110751-50	D50, Girl's room by Library, right sink	Drinking Water	09/21/2016 0731	09/23/2016 1215
420-110751-51	D51, Boy's room by Library, left sink	Drinking Water	09/21/2016 0732	09/23/2016 1215
420-110751-52	D52, Boy's room by Library, center sink	Drinking Water	09/21/2016 0733	09/23/2016 1215
420-110751-53	D53, Boy's room by Library, right sink	Drinking Water	09/21/2016 0733	09/23/2016 1215
420-110751-54	D54, Faculty toilet room by Library, sink	Drinking Water	09/21/2016 0733	09/23/2016 1215
420-110751-55	D55, Principal office toilet room sink	Drinking Water	09/21/2016 0735	09/23/2016 1215
420-110751-56	D56, Nurse office, toilet room sink	Drinking Water	09/21/2016 0736	09/23/2016 1215
420-110751-57	D57, Room 11 sink	Drinking Water	09/21/2016 0737	09/23/2016 1215
420-110751-58	D58, Room 11 toilet room sink	Drinking Water	09/21/2016 0738	09/23/2016 1215
420-110751-59	D59, Room 12 sink	Drinking Water	09/21/2016 0740	09/23/2016 1215
420-110751-60	D60, Room 12 toilet room sink	Drinking Water	09/21/2016 0741	09/23/2016 1215
420-110751-61	D61, Coaches office, toilet room sink	Drinking Water	09/21/2016 0742	09/23/2016 1215
420-110751-62	D62, Boy's room by Gym, left sink	Drinking Water	09/21/2016 0743	09/23/2016 1215
420-110751-63	D63, Boy's room by Gym, center sink	Drinking Water	09/21/2016 0743	09/23/2016 1215
420-110751-64	D64, Girl's room by Gym, center sink	Drinking Water	09/21/2016 0745	09/23/2016 1215

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-110751-1
SDG Number: New Paltz CSD Duzine

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-110751-65	D65, Girl's room by Gym, right sink	Drinking Water	09/21/2016 0745	09/23/2016 1215
420-110751-66	D66, Room 10 sink	Drinking Water	09/21/2016 0746	09/23/2016 1215
420-110751-67	D67, Room 7 sink	Drinking Water	09/21/2016 0747	09/23/2016 1215
420-110751-68	D68, Room 8 sink	Drinking Water	09/21/2016 0748	09/23/2016 1215
420-110751-69	D69, Room 5 sink	Drinking Water	09/21/2016 0750	09/23/2016 1215
420-110751-70	D70, Room 6 sink	Drinking Water	09/21/2016 0751	09/23/2016 1215
420-110751-71	D71. Room 4 sink	Drinking Water	09/21/2016 0752	09/23/2016 1215
420-110751-72	D72, Room 3 sink	Drinking Water	09/21/2016 0753	09/23/2016 1215
420-110751-73	D73, Room 2 sink	Drinking Water	09/21/2016 0755	09/23/2016 1215
420-110751-74	D74, Room 1 sink	Drinking Water	09/21/2016 0756	09/23/2016 1215

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D1, sink in center of kitchen**
Lab Sample ID: **420-110751-1**

Date Sampled: 09/15/2016 0718
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1204	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	6.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D2, sink at back of kitchen**
Lab Sample ID: **420-110751-2**

Date Sampled: 09/15/2016 0719
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1207	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	3.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D3, kitchen toilet room sink**
Lab Sample ID: **420-110751-3**

Date Sampled: 09/15/2016 0719
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1208	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D4, faculty room sink**
Lab Sample ID: **420-110751-4**

Date Sampled: 09/15/2016 0721
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1208	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	3.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D5, Room 24 sink**
Lab Sample ID: **420-110751-5**

Date Sampled: 09/15/2016 0723
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1209	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	3.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D6, Room 24 water fountain**
Lab Sample ID: **420-110751-6**

Date Sampled: 09/15/2016 0723
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1210	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	4.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D7, Room 24 toilet room sink**
Lab Sample ID: **420-110751-7**

Date Sampled: 09/15/2016 0724
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1211	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D8, Room 26 sink**
Lab Sample ID: **420-110751-8**

Date Sampled: 09/15/2016 0727
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1213	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	4.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D9, Room 26 water fountain**
Lab Sample ID: **420-110751-9**

Date Sampled: 09/15/2016 0728
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1214	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	3.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D10, Room 26 toilet room sink**
Lab Sample ID: **420-110751-10**

Date Sampled: 09/15/2016 0729
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1215	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D11, Room 28 sink**
Lab Sample ID: **420-110751-11**

Date Sampled: 09/15/2016 0703
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1215	
Prep Method: 200			Date Prepared:		10/16/2016 0845	
Pb	19	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D12, Room 28 toilet room sink**
Lab Sample ID: **420-110751-12**

Date Sampled: 09/15/2016 0731
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1216	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	9.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D13, Room 30 sink**
Lab Sample ID: **420-110751-13**

Date Sampled: 09/15/2016 0734
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1217	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	5.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D14, Room 30 water fountain**
Lab Sample ID: **420-110751-14**

Date Sampled: 09/15/2016 0734
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1218	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D15, Room 30 toilet room sink**
Lab Sample ID: **420-110751-15**

Date Sampled: 09/15/2016 0735
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1218	
Prep Method: 200			Date Prepared:		10/16/2016 0845	
Pb	15	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D16, Room 32 sink**
Lab Sample ID: **420-110751-16**

Date Sampled: 09/15/2016 0737
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1241	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D17, Room 32 water fountain**
Lab Sample ID: **420-110751-17**

Date Sampled: 09/15/2016 0738
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1242	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	7.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D18, Room 32 toilet room sink**
Lab Sample ID: **420-110751-18**

Date Sampled: 09/15/2016 0739
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1242	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D19, Women's Fac. Restroom by Rm 32, sink**
Lab Sample ID: **420-110751-19**

Date Sampled: 09/15/2016 0740
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1243	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D20, Room 34 sink**
Lab Sample ID: **420-110751-20**

Date Sampled: 09/15/2016 0742
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1244	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	9.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D21, Room 34 toilet room sink**
Lab Sample ID: **420-110751-21**

Date Sampled: 09/15/2016 0742
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1245	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D22, Room 35 sink**
Lab Sample ID: **420-110751-22**

Date Sampled: 09/15/2016 0744
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1248	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	3.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D23, Room 35 water fountain**
Lab Sample ID: **420-110751-23**

Date Sampled: 09/15/2016 0744
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1250	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D24, Room 35 toilet room sink**
Lab Sample ID: **420-110751-24**

Date Sampled: 09/15/2016 0746
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1251	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	4.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D25, lavatory sink next to Room 35**
Lab Sample ID: **420-110751-25**

Date Sampled: 09/15/2016 0747
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1252	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D26, Room 33 sink**
Lab Sample ID: **420-110751-26**

Date Sampled: 09/15/2016 0748
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1252	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	6.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D27, Room 33 water fountain**
Lab Sample ID: **420-110751-27**

Date Sampled: 09/15/2016 0750
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1253	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	9.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D28, Room 31 sink**
Lab Sample ID: **420-110751-28**

Date Sampled: 09/15/2016 0751
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1254	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D29, Room 31 water fountain**
Lab Sample ID: **420-110751-29**

Date Sampled: 09/15/2016 0752
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1255	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D30, Room 31 toilet room sink**
Lab Sample ID: **420-110751-30**

Date Sampled: 09/15/2016 0754
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1256	
Prep Method: 200			Date Prepared:		10/16/2016 0845	
Pb	140	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D31, Room 29 sink**
Lab Sample ID: **420-110751-31**

Date Sampled: 09/15/2016 0755
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1256	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D32, Room water fountain**
Lab Sample ID: **420-110751-32**

Date Sampled: 09/15/2016 0756
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1257	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D33, Room 29 toilet room sink**
Lab Sample ID: **420-110751-33**

Date Sampled: 09/15/2016 0756
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1259	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	5.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D34, Room 27 sink**
Lab Sample ID: **420-110751-34**

Date Sampled: 09/15/2016 0758
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1300	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	3.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D35, Room 27 water fountain**
Lab Sample ID: **420-110751-35**

Date Sampled: 09/15/2016 0759
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1301	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	2.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D36, Room 27 toilet room sink**
Lab Sample ID: **420-110751-36**

Date Sampled: 09/15/2016 0759
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1302	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	7.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D37, Room 25 sink**
Lab Sample ID: **420-110751-37**

Date Sampled: 09/15/2016 0800
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1303	
Prep Method: 200			Date Prepared:		10/16/2016 0845	
Pb	24	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D38, Room 21 sink**
Lab Sample ID: **420-110751-38**

Date Sampled: 09/21/2016 0717
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1303	
Prep Method: 200			Date Prepared:		10/16/2016 0845	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D39, Room 21 water fountain**
Lab Sample ID: **420-110751-39**

Date Sampled: 09/21/2016 0717
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1304	
Prep Method: 200			Date Prepared:		10/16/2016 0845	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D40, Room 19 sink**
Lab Sample ID: **420-110751-40**

Date Sampled: 09/21/2016 0719
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1305	
Prep Method: 200		Date Prepared:		10/16/2016 0845	
Pb	7.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D41, Room 20 sink**
Lab Sample ID: **420-110751-41**

Date Sampled: 09/21/2016 0720
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1306	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	18	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D42, Room 17 sink**
Lab Sample ID: **420-110751-42**

Date Sampled: 09/21/2016 0721
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1310	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	9.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D43, Room 18 sink**
Lab Sample ID: **420-110751-43**

Date Sampled: 09/21/2016 0722
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1311	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	16	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D44, Room 15 sink**
Lab Sample ID: **420-110751-44**

Date Sampled: 09/21/2016 0724
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1312	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	9.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D45, Room 16 sink**
Lab Sample ID: **420-110751-45**

Date Sampled: 09/21/2016 0725
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1313	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	34	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D46, Room 13 sink**
Lab Sample ID: **420-110751-46**

Date Sampled: 09/21/2016 0727
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1313	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D47, Room 14 sink**
Lab Sample ID: **420-110751-47**

Date Sampled: 09/21/2016 0729
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1314	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	22	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D48, Girl's room by Library, left sink**
Lab Sample ID: **420-110751-48**

Date Sampled: 09/21/2016 0730
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1315	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	2.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D49, Girl's room by Library, center sink**
Lab Sample ID: **420-110751-49**

Date Sampled: 09/21/2016 0731
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1316	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D50, Girl's room by Library, right sink**
Lab Sample ID: **420-110751-50**

Date Sampled: 09/21/2016 0731
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1318	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	3.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D51, Boy's room by Library, left sink**
Lab Sample ID: **420-110751-51**

Date Sampled: 09/21/2016 0732
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1319	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	1.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D52, Boy's room by Library, center sink**
Lab Sample ID: **420-110751-52**

Date Sampled: 09/21/2016 0733
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1320	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	1.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D53, Boy's room by Library, right sink**
Lab Sample ID: **420-110751-53**

Date Sampled: 09/21/2016 0733
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1321	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D54, Faculty toilet room by Library, sink**
Lab Sample ID: **420-110751-54**

Date Sampled: 09/21/2016 0733
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1322	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D55, Principal office toilet room sink**
Lab Sample ID: **420-110751-55**

Date Sampled: 09/21/2016 0735
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1323	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	2.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D56, Nurse office, toilet room sink**
Lab Sample ID: **420-110751-56**

Date Sampled: 09/21/2016 0736
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1323	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	7.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D57, Room 11 sink**
Lab Sample ID: **420-110751-57**

Date Sampled: 09/21/2016 0737
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1324	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D58, Room 11 toilet room sink**
Lab Sample ID: **420-110751-58**

Date Sampled: 09/21/2016 0738
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1325	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	3.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D59, Room 12 sink**
Lab Sample ID: **420-110751-59**

Date Sampled: 09/21/2016 0740
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1327	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	5.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D60, Room 12 toilet room sink**
Lab Sample ID: **420-110751-60**

Date Sampled: 09/21/2016 0741
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1328	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	7.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D61, Coaches office, toilet room sink**
Lab Sample ID: **420-110751-61**

Date Sampled: 09/21/2016 0742
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1329	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	9.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D62, Boy's room by Gym, left sink**
Lab Sample ID: **420-110751-62**

Date Sampled: 09/21/2016 0743
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1332	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	1.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D63, Boy's room by Gym, center sink**
Lab Sample ID: **420-110751-63**

Date Sampled: 09/21/2016 0743
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/19/2016 1333	
Prep Method: 200				Date Prepared:	10/16/2016 0900	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D64, Girl's room by Gym, center sink**
Lab Sample ID: **420-110751-64**

Date Sampled: 09/21/2016 0745
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1334	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	2.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D65, Girl's room by Gym, right sink**
Lab Sample ID: **420-110751-65**

Date Sampled: 09/21/2016 0745
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/19/2016 1334	
Prep Method: 200				Date Prepared:	10/16/2016 0900	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D66, Room 10 sink**
Lab Sample ID: **420-110751-66**

Date Sampled: 09/21/2016 0746
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1337	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	16	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D67, Room 7 sink**
Lab Sample ID: **420-110751-67**

Date Sampled: 09/21/2016 0747
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1338	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D68, Room 8 sink**
Lab Sample ID: **420-110751-68**

Date Sampled: 09/21/2016 0748
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1338	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	17	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D69, Room 5 sink**
Lab Sample ID: **420-110751-69**

Date Sampled: 09/21/2016 0750
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1339	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	11	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D70, Room 6 sink**
Lab Sample ID: **420-110751-70**

Date Sampled: 09/21/2016 0751
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1340	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	16	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D71. Room 4 sink**
Lab Sample ID: **420-110751-71**

Date Sampled: 09/21/2016 0752
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1341	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	17	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D72, Room 3 sink**
Lab Sample ID: **420-110751-72**

Date Sampled: 09/21/2016 0753
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1341	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D73, Room 2 sink**
Lab Sample ID: **420-110751-73**

Date Sampled: 09/21/2016 0755
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/19/2016 1342	
Prep Method: 200			Date Prepared:		10/16/2016 0900	
Pb	29	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-110751-1
Sdg Number: New Paltz CSD Duzine

Client Sample ID: **D74, Room 1 sink**
Lab Sample ID: **420-110751-74**

Date Sampled: 09/21/2016 0756
Date Received: 09/23/2016 1215
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/19/2016 1343	
Prep Method: 200		Date Prepared:		10/16/2016 0900	
Pb	12	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: New Paltz CSD Duzine

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolpthalien Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: New Paltz CSD Duzine

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only): 110751

PROJECT REFERENCE: New Paltz CSD Duzine	PROJECT NO.	PROJECT LOCATION: Duzine
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

PAGE 1 of 6 — 1

TURNAROUND TIME: NORMAL _____ QUICK _____ VERBAL _____

#OF COOLERS

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/15/2016	7:18	D1, sink in center of ktichen						1			1							Lead (DW 200.8)
9/15/2016	7:19	D2, sink at back of kitchen						1			1							Lead (DW 200.8)
9/15/2016	7:19	D3, kitchen toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:21	D4, faculty room sink						1			1							Lead (DW 200.8)
9/15/2016	7:23	D5, Room 24 sink						1			1							Lead (DW 200.8)
9/15/2016	7:23	D6, Room 24 water fountain						1			1							Lead (DW 200.8)
9/15/2016	7:24	D7, Room 24 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:27	D8, Room 26 sink						1			1							Lead (DW 200.8)
9/15/2016	7:28	D9, Room 26 water fountain						1			1							Lead (DW 200.8)
9/15/2016	7:29	D10, Room 26 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:31	D11, Room 28 sink						1			1							Lead (DW 200.8)
9/15/2016	7:31	D12, Room 28 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:34	D13, Room 30 sink						1			1							Lead (DW 200.8)

NUMBER OF CONTAINERS SUBMITTED

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Bum Gomba	Ulster BOCES	9/23/16	12:15pm				
SAMPLED BY: (SIGNATURE) Bum Gomba	COMPANY Ulster BOCES	DATE 9/23/16	TIME 12:15pm	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:
[signature]	9/23/16	1215	YES / NO	12#3 23.5	ICE (Y___N✓) pH____ CL2____ Reveiwed by_____

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only): 110751

PAGE 2 of 6 | 1

PROJECT REFERENCE: New Paltz CSD Duzine	PROJECT NO.:	PROJECT LOCATION: Duzine
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER:	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX:
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES / NUMBER OF CONTAINERS SUBMITTED

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/15/2016	7:34	D14, Room 30 water fountain						1			1							Lead (DW 200.8)
9/15/2016	7:35	D15, Room 30 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:37	D16, Room 32 sink						1			1							Lead (DW 200.8)
9/15/2016	7:38	D17, Room 32 water fountain						1			1							Lead (DW 200.8)
9/15/2016	7:39	D18, Room 32 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:40	D19, Women's Fac. Restroom by Rm 32, sink						1			1							Lead (DW 200.8)
9/15/2016	7:42	D20, Room 34 sink						1			1							Lead (DW 200.8)
9/15/2016	7:42	D21, Room 34 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:44	D22, Room 35 sink						1			1							Lead (DW 200.8)
9/15/2016	7:44	D23, Room 35 water fountain						1			1							Lead (DW 200.8)
9/15/2016	7:46	D24, Room 35 toilet room sink						1			1							Lead (DW 200.8)
9/15/2016	7:47	D25, lavatory sink next to Room 35						1			1							Lead (DW 200.8)
9/15/2016	7:48	D26, Room 33 sink						1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Crowder	Ulster BOCES	9/23/16	12:15pm				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Crowder	Ulster BOCES	9/23/16	12:15pm				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:
[signature]	9/23/16	1215	YES / NO	1R#3 Cooler Temp(C): 235	ICE (Y___N✓) pH____ CL2____ Reveiwed by_____

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only): 110751

PAGE 3 of 6 — 1

PROJECT REFERENCE: New Paltz CSD Duzine	PROJECT NO.	PROJECT LOCATION: Duzine
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES — NUMBER OF CONTAINERS SUBMITTED

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/15/2016	7:50	D27, Room 33 water fountain	1			1							Lead (DW 200.8)
9/15/2016	7:51	D28, Room 31 sink	1			1							Lead (DW 200.8)
9/15/2016	7:52	D29, Room 31 water fountain	1			1							Lead (DW 200.8)
9/15/2016	7:54	D30, Room 31 toilet room sink	1			1							Lead (DW 200.8)
9/15/2016	7:55	D31, Room 29 sink	1			1							Lead (DW 200.8)
9/15/2016	7:56	D32, Room water fountain	1			1							Lead (DW 200.8)
9/15/2016	7:56	D33, Room 29 toilet room sink	1			1							Lead (DW 200.8)
9/15/2016	7:58	D34, Room 27 sink	1			1							Lead (DW 200.8)
9/15/2016	7:59	D35, Room 27 water fountain	1			1							Lead (DW 200.8)
9/15/2016	7:59	D36, Room 27 toilet room sink	1			1							Lead (DW 200.8)
9/15/2016	8:00	D37, Room 25 sink	1			1							Lead (DW 200.8)
* 9/21/2016	7:17	D38, Room 21 sink	1			1							Lead (DW 200.8)
* 9/21/2016	7:17	D39, Room 21 water fountain	1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME
Brian Coondra	Ulster BOCES	9/23/16	12:15pm				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME
Brian Coondra	Ulster BOCES	9/23/16	12:15pm				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPANY	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS: ICE (Y__N__) pH____ CL2____ Reveiwed by____
[signature]	9/23/15	1215		1R#3 23.5	* Pre-preserved with Nitric acid @ ETL KM 9/23/16

Nitric acid man'f by Fisher Chemical Lot # 161446

10/31/2016

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only): 110751

PAGE 4 of 6 | 1

PROJECT REFERENCE: New Paltz CSD Duzine	PROJECT NO.	PROJECT LOCATION: Duzine
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

NUMBER OF CONTAINERS SUBMITTED

	SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
*	9/21/2016	7:19	D40, Room 19 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:20	D41, Room 20 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:21	D42, Room 17 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:22	D43, Room 18 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:24	D44, Room 15 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:25	D45, Room 16 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:27	D46, Room 13 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:29	D47, Room 14 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:30	D48, Girl's room by Library, left sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:31	D49, Girl's room by Library, center sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:31	D50, Girl's room by Library, right sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:32	D51, Boy's room by Library, left sink						1			1							Lead (DW 200.8)
	9/21/2016	7:33	D52, Boy's room by Library, center sink						1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Colombo	Ulster BOCES	9/23/16	12:15pm				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Colombo	Ulster BOCES	9/23/16	12:15pm				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS: ICE (Y__N✓) pH____ CL2____ Reveiwed by____
[signature]	9/23/16	1215		23.5 IR#3	* Pre-preserved with Nitric acid @ ETL KM 9/23/16

Nitric acid man'f by Fisher Chemical Lot # 161446

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only): 110751

PROJECT REFERENCE: New Paltz CSD Duzine	PROJECT NO.	PROJECT LOCATION: Duzine
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

PAGE 5 of 6 — 1

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

	SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
*	9/21/2016	7:33	D53, Boy's room by Library, right sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:33	D54, Faculty toilet room by Library, sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:35	D55, Principal office toilet room sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:36	D56, Nurse office, toilet room sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:37	D57, Room 11 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:38	D58, Room 11 toilet room sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:40	D59, Room 12 sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:41	D60, Room 12 toilet room sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:42	D61, Coaches office, toilet room sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:43	D62, Boy's room by Gym, left sink						1			1							Lead (DW 200.8)
	9/21/2016	7:43	D63, Boy's room by Gym, center sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:45	D64, Girl's room by Gym, center sink						1			1							Lead (DW 200.8)
*	9/21/2016	7:45	D65, Girl's room by Gym, right sink						1			1							Lead (DW 200.8)

NUMBER OF CONTAINERS SUBMITTED

RELINQUISHED BY: (SIGNATURE) Brian Chamber	COMPANY Ulster BOCES	DATE 9/23/16	TIME 12:15pm	RECEIVED BY: (SIGNATURE)	COMPA / DATE / TIME
SAMPLED BY: (SIGNATURE) Brian Chamber	COMPANY Ulster BOCES	DATE 9/23/16	TIME 12:15pm	RECEIVED BY: (SIGNATURE)	COMPA / DATE / TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA / DATE / TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:
[illegible]	9/23/16	1215	YES / NO	23.5	ICE (Y___N✓) pH____ CL2____ Reveiwed by KM 9/23/16

* Pre-preserved with Nitric acid @ ETL

Nitric acid man'f by Fisher Chemical Lot # 161446

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only): 110571

PAGE 6 of 6 — 1

PROJECT REFERENCE: New Paltz CSD Duzine	PROJECT NO.	PROJECT LOCATION: Duzine
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES — NUMBER OF CONTAINERS SUBMITTED

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid *	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/21/2016	7:46	D66, Room 10 sink	1			1							Lead (DW 200.8)
9/21/2016	7:47	D67, Room 7 sink	1			1							Lead (DW 200.8)
9/21/2016	7:48	D68, Room 8 sink	1			1							Lead (DW 200.8)
9/21/2016	7:50	D69, Room 5 sink	1			1							Lead (DW 200.8)
9/21/2016	7:51	D70, Room 6 sink	1			1							Lead (DW 200.8)
9/21/2016	7:52	D71, Room 4 sink	1			1							Lead (DW 200.8)
9/21/2016	7:53	D72, Room 3 sink	1			1							Lead (DW 200.8)
9/21/2016	7:55	D73, Room 2 sink	1			1							Lead (DW 200.8)
9/21/2016	7:56	D74, Room 1 sink	1			1							Lead (DW 200.8)
			1			1							Lead (DW 200.8)
			1			1							Lead (DW 200.8)
			1			1							Lead (DW 200.8)
			1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
[signature]	Ulster BOCES	9/23/16	12:15pm				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
[signature]	Ulster BOCES	9/23/16	12:15pm				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

1R#3

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS: ICE (Y__N__) pH____ CL2____ Reveiwed by____
[signature]	9/23/16	1215		23.5	* Pre-preserved with Nitric acid @ ETL KM 9/23/16

Nitric acid man'f by Fisher Chemical Lot # 161446

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-110751-1
SDG Number: New Paltz CSD Duzine

Login Number: **110751**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	23.5 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	Prepreserved with nitric acid at lab. KM 9/23/16
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

EnviroTest Laboratories Inc.

ANALYTICAL REPORT

Job Number: 420-111024-1

SDG Number: New Paltz CSD Lenape

Job Description: Ulster BOCES

For:
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Attention: Michael O'Rourke

Meredith Ruthven

Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
10/31/2016

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories Inc. certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative.

EnviroTest Laboratories, Inc. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Palentino, Gus J	GJP

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111024-1	L01 Kitchen 2 Bay Sink left Faucet	Drinking Water	09/28/2016 0639	09/29/2016 1025
420-111024-2	L02 Kitchen 2 Bay Sink right Faucet	Drinking Water	09/28/2016 0640	09/29/2016 1025
420-111024-3	L03 Kitchen center Sink Faucet	Drinking Water	09/28/2016 0642	09/29/2016 1025
420-111024-4	L04 Kitchen Handwashing sink	Drinking Water	09/28/2016 0646	09/29/2016 1025
420-111024-5	L05 Kitchen coffee pot sink	Drinking Water	09/28/2016 0646	09/29/2016 1025
420-111024-6	L06 Room 115 sink facuet	Drinking Water	09/28/2016 0648	09/29/2016 1025
420-111024-7	L07Room 116A sink faucet	Drinking Water	09/28/2016 0649	09/29/2016 1025
420-111024-8	L08 Room 119 TR Sink Faucet	Drinking Water	09/28/2016 0651	09/29/2016 1025
420-111024-9	L09 Room 119 Sink Faucet	Drinking Water	09/28/2016 0652	09/29/2016 1025
420-111024-10	L10 Room 118 Sink Faucet	Drinking Water	09/28/2016 0652	09/29/2016 1025
420-111024-11	L11 Room 121 Sink Faucet	Drinking Water	09/28/2016 0654	09/29/2016 1025
420-111024-12	L12 Room 121 TR Sink Faucet	Drinking Water	09/28/2016 0654	09/29/2016 1025
420-111024-13	L13 Cafeteria water fountain	Drinking Water	09/28/2016 0658	09/29/2016 1025
420-111024-14	L14 Boy's room by Gym left Sink Faucet	Drinking Water	09/28/2016 0701	09/29/2016 1025
420-111024-15	L15 Boy's room by Gym 2nd to left Sink Faucet	Drinking Water	09/28/2016 0702	09/29/2016 1025
420-111024-16	L16 Boy's Rm by Gym 2nd from right Sink Faucet	Drinking Water	09/28/2016 0702	09/29/2016 1025
420-111024-17	L17 Boy's room by Gym right Sink Faucet	Drinking Water	09/28/2016 0702	09/29/2016 1025
420-111024-18	L18 WF by Gym, lower left fountain	Drinking Water	09/28/2016 0703	09/29/2016 1025
420-111024-19	L19 WF by Gym, upper left fountain	Drinking Water	09/28/2016 0703	09/29/2016 1025
420-111024-20	L20 WF by Gym lower right fountain	Drinking Water	09/28/2016 0704	09/29/2016 1025
420-111024-21	L21 WF by Gym upper right fountain	Drinking Water	09/28/2016 0704	09/29/2016 1025
420-111024-22	L22 Girl's room by gym left Sink Faucet	Drinking Water	09/28/2016 0705	09/29/2016 1025
420-111024-23	L23 Girl's room by Gym 2nd Sink from right faucet	Drinking Water	09/28/2016 0706	09/29/2016 1025
420-111024-24	L24 Girl's room by Gym right Sink Faucet	Drinking Water	09/28/2016 0706	09/29/2016 1025
420-111024-25	L25 Room 101 Sink Faucet	Drinking Water	09/28/2016 0710	09/29/2016 1025
420-111024-26	L26 Room 101 water fountain	Drinking Water	09/28/2016 0710	09/29/2016 1025
420-111024-27	L27 Room 103 Sink Faucet	Drinking Water	09/28/2016 0712	09/29/2016 1025
420-111024-28	L28 Room 103 water fountain	Drinking Water	09/28/2016 0712	09/29/2016 1025
420-111024-29	L29 Room 124 left Sink Faucet	Drinking Water	09/28/2016 0714	09/29/2016 1025
420-111024-30	L30 Room 102 left Sink Faucet	Drinking Water	09/28/2016 0715	09/29/2016 1025

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111024-31	L31 Room 102 Right Sink Faucet	Drinking Water	09/28/2016 0715	09/29/2016 1025
420-111024-32	L32 Room 124 right Sink Faucet	Drinking Water	09/28/2016 0715	09/29/2016 1025
420-111024-33	L33 Room 124 TR Sink Faucet	Drinking Water	09/28/2016 0715	09/29/2016 1025
420-111024-34	L34 Room 102 water fountain	Drinking Water	09/28/2016 0716	09/29/2016 1025
420-111024-35	L35 Room 102 TR Sink Faucet	Drinking Water	09/28/2016 0716	09/29/2016 1025
420-111024-36	L36 Room 104 left Sink Faucet	Drinking Water	09/28/2016 0720	09/29/2016 1025
420-111024-37	L37 Room 104 right Sink Faucet	Drinking Water	09/28/2016 0720	09/29/2016 1025
420-111024-38	L38 Room 104 water fountain	Drinking Water	09/28/2016 0720	09/29/2016 1025
420-111024-39	L39 Room 104 TR Sink Faucet	Drinking Water	09/28/2016 0721	09/29/2016 1025
420-111024-40	L40 Room 105 Sink Faucet	Drinking Water	09/28/2016 0722	09/29/2016 1025
420-111024-41	L41 Room 105 water fountain	Drinking Water	09/28/2016 0722	09/29/2016 1025
420-111024-42	L42 Room 107 Sink Faucet	Drinking Water	09/28/2016 0723	09/29/2016 1025
420-111024-43	L43 Room 107 water fountain	Drinking Water	09/28/2016 0724	09/29/2016 1025
420-111024-44	L44 Room 109 Sink Faucet	Drinking Water	09/28/2016 0725	09/29/2016 1025
420-111024-45	L45 Room 109 water fountain	Drinking Water	09/28/2016 0725	09/29/2016 1025
420-111024-46	L46 Room 110 Sink Faucet	Drinking Water	09/28/2016 0726	09/29/2016 1025
420-111024-47	L47 Room 110 water fountain	Drinking Water	09/28/2016 0726	09/29/2016 1025
420-111024-48	L48 Room 111 Sink Faucet	Drinking Water	09/28/2016 0727	09/29/2016 1025
420-111024-49	L49 Room 111 water fountain	Drinking Water	09/28/2016 0727	09/29/2016 1025
420-111024-50	L50 Nurse's office Sink Faucet	Drinking Water	09/28/2016 0729	09/29/2016 1025
420-111024-51	L51 Nurse's Office TR Sink Faucet	Drinking Water	09/28/2016 0729	09/29/2016 1025
420-111024-52	L52 Women's room by Main Office left Sink Faucet	Drinking Water	09/28/2016 0731	09/29/2016 1025
420-111024-53	L53 Women's Rm by Main Office right Sink Faucet	Drinking Water	09/28/2016 0731	09/29/2016 1025
420-111024-54	L54 water fountain outside Main Office	Drinking Water	09/28/2016 0735	09/29/2016 1025
420-111024-55	L55 Men's room by Main Office left Sink Faucet	Drinking Water	09/28/2016 0733	09/29/2016 1025
420-111024-56	L56 Men's Room by Main Office right Sink Faucet	Drinking Water	09/28/2016 0733	09/29/2016 1025
420-111024-57	L57 Room 201 Sink Faucet	Drinking Water	09/28/2016 0638	09/29/2016 1025
420-111024-58	L58 Room 201 water fountain	Drinking Water	09/28/2016 0638	09/29/2016 1025
420-111024-59	L59 Room 202 Sink Faucet	Drinking Water	09/28/2016 0639	09/29/2016 1025
420-111024-60	L60 Room 202 water fountain	Drinking Water	09/28/2016 0639	09/29/2016 1025

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111024-61	L61 Room 203 Sink Faucet	Drinking Water	09/28/2016 0640	09/29/2016 1025
420-111024-62	L62 Room 203 water fountain	Drinking Water	09/28/2016 0640	09/29/2016 1025
420-111024-63	L63 Room 204 Sink Faucet	Drinking Water	09/28/2016 0642	09/29/2016 1025
420-111024-64	L64 Room 204 water fountain	Drinking Water	09/28/2016 0642	09/29/2016 1025
420-111024-65	L65 Room 205 Sink Faucet	Drinking Water	09/28/2016 0643	09/29/2016 1025
420-111024-66	L66 Room 205 water fountain	Drinking Water	09/28/2016 0643	09/29/2016 1025
420-111024-67	L67 Room 206 Sink Faucet	Drinking Water	09/28/2016 0645	09/29/2016 1025
420-111024-68	L68 Room 206 water fountain	Drinking Water	09/28/2016 0645	09/29/2016 1025
420-111024-69	L69 Faculty men's room near Rm 206, left sink	Drinking Water	09/28/2016 0647	09/29/2016 1025
420-111024-70	L70 Faculty men's room near Rm 206, right sink	Drinking Water	09/28/2016 0648	09/29/2016 1025
420-111024-71	L71 Fac. Women's room near Rm 206, left sink	Drinking Water	09/28/2016 0648	09/29/2016 1025
420-111024-72	L72 Room 207Sink Faucet	Drinking Water	09/28/2016 0649	09/29/2016 1025
420-111024-73	L73 Room 207 water fountain	Drinking Water	09/28/2016 0649	09/29/2016 1025
420-111024-74	L74 Room 209 Sink Faucet	Drinking Water	09/28/2016 0651	09/29/2016 1025
420-111024-75	L75 Room 209 water fountain	Drinking Water	09/28/2016 0651	09/29/2016 1025
420-111024-76	L76 Room 210 Sink Faucet	Drinking Water	09/28/2016 0652	09/29/2016 1025
420-111024-77	L77 Room 210 water fountain	Drinking Water	09/28/2016 0652	09/29/2016 1025
420-111024-78	L78 Room 211 Sink Faucet	Drinking Water	09/28/2016 0654	09/29/2016 1025
420-111024-79	L79 Room 211 water fountain	Drinking Water	09/28/2016 0654	09/29/2016 1025
420-111024-80	L80 Room 208 left Sink Faucet	Drinking Water	09/28/2016 0656	09/29/2016 1025
420-111024-81	L81 Rom 208 right Sink Faucet	Drinking Water	09/28/2016 0656	09/29/2016 1025
420-111024-82	L82 lower water fountain by Room 212	Drinking Water	09/28/2016 0658	09/29/2016 1025
420-111024-83	L83 upper water fountain by Room 212	Drinking Water	09/28/2016 0658	09/29/2016 1025
420-111024-84	L84 Library Sink Faucet	Drinking Water	09/28/2016 0659	09/29/2016 1025
420-111024-85	L85 Room 216 far left Sink Faucet	Drinking Water	09/28/2016 0702	09/29/2016 1025
420-111024-86	L86 Room 216 corner right Sink Faucet	Drinking Water	09/28/2016 0702	09/29/2016 1025
420-111024-87	L87 Room 216 far right Sink Faucet	Drinking Water	09/28/2016 0703	09/29/2016 1025
420-111024-88	L88 Rom 216 left Sink Faucet under tarpon	Drinking Water	09/28/2016 0704	09/29/2016 1025
420-111024-89	L89 Room 216 right Sink Faucet under tarpon	Drinking Water	09/28/2016 0704	09/29/2016 1025
420-111024-90	L90 Room 215 Sink Faucet	Drinking Water	09/28/2016 0705	09/29/2016 1025
420-111024-91	L91 Rom 215 water fountain	Drinking Water	09/28/2016 0706	09/29/2016 1025

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-111024-92	L92 Room 217 Sink Faucet	Drinking Water	09/28/2016 0707	09/29/2016 1025
420-111024-93	L93 Room 217 water fountain	Drinking Water	09/28/2016 0707	09/29/2016 1025
420-111024-94	L94 Room 218 Sink Faucet	Drinking Water	09/28/2016 0708	09/29/2016 1025
420-111024-95	L95 Room 218 water fountain	Drinking Water	09/28/2016 0708	09/29/2016 1025
420-111024-96	L96 Room 219 Sink Faucet	Drinking Water	09/28/2016 0710	09/29/2016 1025
420-111024-97	L97 Room 219 water fountain	Drinking Water	09/28/2016 0710	09/29/2016 1025
420-111024-98	L98 Room 222 Sink Faucet	Drinking Water	09/28/2016 0712	09/29/2016 1025
420-111024-99	L99 Room 222 Water fountain	Drinking Water	09/28/2016 0712	09/29/2016 1025
420-111024-100	L100 Room 221 Sink Faucet	Drinking Water	09/28/2016 0713	09/29/2016 1025
420-111024-101	L101 Room 221 water fountain	Drinking Water	09/28/2016 0713	09/29/2016 1025
420-111024-102	L102 Room 224 Sink Faucet	Drinking Water	09/28/2016 0715	09/29/2016 1025
420-111024-103	L103 Room 224 water fountain	Drinking Water	09/28/2016 0715	09/29/2016 1025
420-111024-104	L104 Room 223 Sink Faucet	Drinking Water	09/28/2016 0716	09/29/2016 1025
420-111024-105	L105 Room 223 water fountain	Drinking Water	09/28/2016 0716	09/29/2016 1025
420-111024-106	L106 Room 226 Sink Faucet	Drinking Water	09/28/2016 0718	09/29/2016 1025
420-111024-107	L107 Room 226 water fountain	Drinking Water	09/28/2016 0718	09/29/2016 1025
420-111024-108	L108Room 225 Sink Faucet	Drinking Water	09/28/2016 0720	09/29/2016 1025

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L01 Kitchen 2 Bay Sink left Faucet**
Lab Sample ID: **420-111024-1**

Date Sampled: 09/28/2016 0639
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1751	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L02 Kitchen 2 Bay Sink right Faucet**
Lab Sample ID: **420-111024-2**

Date Sampled: 09/28/2016 0640
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1753	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	2.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L03 Kitchen center Sink Faucet**
Lab Sample ID: **420-111024-3**

Date Sampled: 09/28/2016 0642
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1754	
Prep Method: 200			Date Prepared:		10/25/2016 1330	
Pb	53	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L04 Kitchen Handwashing sink**
Lab Sample ID: **420-111024-4**

Date Sampled: 09/28/2016 0646
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1756	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	2.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L05 Kitchen coffee pot sink**
Lab Sample ID: **420-111024-5**

Date Sampled: 09/28/2016 0646
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/25/2016 1758	
Prep Method: 200				Date Prepared:	10/25/2016 1330	
Pb	41	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L06 Room 115 sink facuet**
Lab Sample ID: **420-111024-6**

Date Sampled: 09/28/2016 0648
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1800	
Prep Method: 200			Date Prepared:		10/25/2016 1330	
Pb	19	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L07Room 116A sink faucet**
Lab Sample ID: **420-111024-7**

Date Sampled: 09/28/2016 0649
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1806	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L08 Room 119 TR Sink Faucet**
Lab Sample ID: **420-111024-8**

Date Sampled: 09/28/2016 0651
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1808	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	8.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L09 Room 119 Sink Faucet**
Lab Sample ID: **420-111024-9**

Date Sampled: 09/28/2016 0652
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1809	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	2.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L10 Room 118 Sink Faucet**
Lab Sample ID: **420-111024-10**

Date Sampled: 09/28/2016 0652
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1811	
Prep Method: 200			Date Prepared:		10/25/2016 1330	
Pb	26	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L11 Room 121 Sink Faucet**
Lab Sample ID: **420-111024-11**

Date Sampled: 09/28/2016 0654
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1813	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	5.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L12 Room 121 TR Sink Faucet**
Lab Sample ID: **420-111024-12**

Date Sampled: 09/28/2016 0654
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/25/2016 1815	
Prep Method: 200				Date Prepared:	10/25/2016 1330	
Pb	16	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L13 Cafeteria water fountain**
Lab Sample ID: **420-111024-13**

Date Sampled: 09/28/2016 0658
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1817	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L14 Boy's room by Gym left Sink Faucet**
Lab Sample ID: **420-111024-14**

Date Sampled: 09/28/2016 0701
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/25/2016 1828	
Prep Method: 200			Date Prepared:	10/25/2016 1330	
Pb	6.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L15 Boy's room by Gym 2nd to left Sink Faucet**
Lab Sample ID: **420-111024-15**

Date Sampled: 09/28/2016 0702
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/25/2016 1830	
Prep Method: 200			Date Prepared:	10/25/2016 1330	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L16 Boy's Rm by Gym 2nd from right Sink**
Lab Sample ID: **420-111024-16**

Date Sampled: 09/28/2016 0702
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1832	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	9.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L17 Boy's room by Gym right Sink Faucet**
Lab Sample ID: **420-111024-17**

Date Sampled: 09/28/2016 0702
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/25/2016 1834	
Prep Method: 200			Date Prepared:	10/25/2016 1330	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L18 WF by Gym, lower left fountain**
Lab Sample ID: **420-111024-18**

Date Sampled: 09/28/2016 0703
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/25/2016 1836	
Prep Method: 200				Date Prepared:	10/25/2016 1330	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L19 WF by Gym, upper left fountain**
Lab Sample ID: **420-111024-19**

Date Sampled: 09/28/2016 0703
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/25/2016 1837	
Prep Method: 200				Date Prepared:	10/25/2016 1330	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L20 WF by Gym lower right fountain**
Lab Sample ID: **420-111024-20**

Date Sampled: 09/28/2016 0704
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1839	
Prep Method: 200			Date Prepared:		10/25/2016 1330	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L21 WF by Gym upper right fountain**
Lab Sample ID: **420-111024-21**

Date Sampled: 09/28/2016 0704
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1841	
Prep Method: 200			Date Prepared:		10/25/2016 1330	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L22 Girl's room by gym left Sink Faucet**
Lab Sample ID: **420-111024-22**

Date Sampled: 09/28/2016 0705
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/25/2016 1843	
Prep Method: 200			Date Prepared:	10/25/2016 1330	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L23 Girl's room by Gym 2nd Sink from right**
Lab Sample ID: **420-111024-23**

Date Sampled: 09/28/2016 0706
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	10/25/2016 1845	
Prep Method: 200			Date Prepared:	10/25/2016 1330	
Pb	5.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L24 Girl's room by Gym right Sink Faucet**
Lab Sample ID: **420-111024-24**

Date Sampled: 09/28/2016 0706
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1851	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	5.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L25 Room 101 Sink Faucet**
Lab Sample ID: **420-111024-25**

Date Sampled: 09/28/2016 0710
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1852	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	6.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L26 Room 101 water fountain**
Lab Sample ID: **420-111024-26**

Date Sampled: 09/28/2016 0710
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1854	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	1.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L27 Room 103 Sink Faucet**
Lab Sample ID: **420-111024-27**

Date Sampled: 09/28/2016 0712
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1856	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L28 Room 103 water fountain**
Lab Sample ID: **420-111024-28**

Date Sampled: 09/28/2016 0712
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1858	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L29 Room 124 left Sink Faucet**
Lab Sample ID: **420-111024-29**

Date Sampled: 09/28/2016 0714
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1900	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	4.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L30 Room 102 left Sink Faucet**
Lab Sample ID: **420-111024-30**

Date Sampled: 09/28/2016 0715
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1902	
Prep Method: 200			Date Prepared:		10/25/2016 1330	
Pb	26	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L31 Room 102 Right Sink Faucet**
Lab Sample ID: **420-111024-31**

Date Sampled: 09/28/2016 0715
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1904	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	9.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L32 Room 124 right Sink Faucet**
Lab Sample ID: **420-111024-32**

Date Sampled: 09/28/2016 0715
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1906	
Prep Method: 200		Date Prepared:		10/25/2016 1330	
Pb	4.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L33 Room 124 TR Sink Faucet**
Lab Sample ID: **420-111024-33**

Date Sampled: 09/28/2016 0715
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1908	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	2.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L34 Room 102 water fountain**
Lab Sample ID: **420-111024-34**

Date Sampled: 09/28/2016 0716
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1919	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	2.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L35 Room 102 TR Sink Faucet**
Lab Sample ID: **420-111024-35**

Date Sampled: 09/28/2016 0716
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1921	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	2.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L36 Room 104 left Sink Faucet**
Lab Sample ID: **420-111024-36**

Date Sampled: 09/28/2016 0720
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/25/2016 1923	
Prep Method: 200				Date Prepared:	10/25/2016 1500	
Pb	19	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L37 Room 104 right Sink Faucet**
Lab Sample ID: **420-111024-37**

Date Sampled: 09/28/2016 0720
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1925	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L38 Room 104 water fountain**
Lab Sample ID: **420-111024-38**

Date Sampled: 09/28/2016 0720
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 1926	
Prep Method: 200			Date Prepared:		10/25/2016 1500	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L39 Room 104 TR Sink Faucet**
Lab Sample ID: **420-111024-39**

Date Sampled: 09/28/2016 0721
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1928	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L40 Room 105 Sink Faucet**
Lab Sample ID: **420-111024-40**

Date Sampled: 09/28/2016 0722
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1930	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	8.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L41 Room 105 water fountain**
Lab Sample ID: **420-111024-41**

Date Sampled: 09/28/2016 0722
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1936	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	3.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L42 Room 107 Sink Faucet**
Lab Sample ID: **420-111024-42**

Date Sampled: 09/28/2016 0723
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1938	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	10	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L43 Room 107 water fountain**
Lab Sample ID: **420-111024-43**

Date Sampled: 09/28/2016 0724
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1940	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L44 Room 109 Sink Faucet**
Lab Sample ID: **420-111024-44**

Date Sampled: 09/28/2016 0725
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1942	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L45 Room 109 water fountain**
Lab Sample ID: **420-111024-45**

Date Sampled: 09/28/2016 0725
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1943	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	2.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L46 Room 110 Sink Faucet**
Lab Sample ID: **420-111024-46**

Date Sampled: 09/28/2016 0726
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1945	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	5.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L47 Room 110 water fountain**
Lab Sample ID: **420-111024-47**

Date Sampled: 09/28/2016 0726
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1947	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L48 Room 111 Sink Faucet**
Lab Sample ID: **420-111024-48**

Date Sampled: 09/28/2016 0727
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1949	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	5.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L49 Room 111 water fountain**
Lab Sample ID: **420-111024-49**

Date Sampled: 09/28/2016 0727
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1951	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	1.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L50 Nurse's office Sink Faucet**
Lab Sample ID: **420-111024-50**

Date Sampled: 09/28/2016 0729
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1953	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L51 Nurse's Office TR Sink Faucet**
Lab Sample ID: **420-111024-51**

Date Sampled: 09/28/2016 0729
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 1959	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L52 Women's room by Main Office left Sink**
Lab Sample ID: **420-111024-52**

Date Sampled: 09/28/2016 0731
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2001	
Prep Method: 200		Date Prepared:		10/25/2016 1500	
Pb	1.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L53 Women's Rm by Main Office right Sink**
Lab Sample ID: **420-111024-53**

Date Sampled: 09/28/2016 0731
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2002	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	2.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L54 water fountain outside Main Office**
Lab Sample ID: **420-111024-54**

Date Sampled: 09/28/2016 0735
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2010	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	5.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L55 Men's room by Main Office left Sink Faucet**
Lab Sample ID: **420-111024-55**

Date Sampled: 09/28/2016 0733
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2012	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	6.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L56 Men's Room by Main Office right Sink**
Lab Sample ID: **420-111024-56**

Date Sampled: 09/28/2016 0733
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2014	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	7.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L57 Room 201 Sink Faucet**
Lab Sample ID: **420-111024-57**

Date Sampled: 09/28/2016 0638
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2016	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	9.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L58 Room 201 water fountain**
Lab Sample ID: **420-111024-58**

Date Sampled: 09/28/2016 0638
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 2022	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L59 Room 202 Sink Faucet**
Lab Sample ID: **420-111024-59**

Date Sampled: 09/28/2016 0639
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2023	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	9.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L60 Room 202 water fountain**
Lab Sample ID: **420-111024-60**

Date Sampled: 09/28/2016 0639
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 2025	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L61 Room 203 Sink Faucet**
Lab Sample ID: **420-111024-61**

Date Sampled: 09/28/2016 0640
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2027	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L62 Room 203 water fountain**
Lab Sample ID: **420-111024-62**

Date Sampled: 09/28/2016 0640
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2029	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	1.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L63 Room 204 Sink Faucet**
Lab Sample ID: **420-111024-63**

Date Sampled: 09/28/2016 0642
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2031	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	8.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L64 Room 204 water fountain**
Lab Sample ID: **420-111024-64**

Date Sampled: 09/28/2016 0642
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 2033	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L65 Room 205 Sink Faucet**
Lab Sample ID: **420-111024-65**

Date Sampled: 09/28/2016 0643
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2035	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	8.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L66 Room 205 water fountain**
Lab Sample ID: **420-111024-66**

Date Sampled: 09/28/2016 0643
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 2037	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L67 Room 206 Sink Faucet**
Lab Sample ID: **420-111024-67**

Date Sampled: 09/28/2016 0645
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 1003	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	13	ug/L	2.0	2.0	2.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L68 Room 206 water fountain**
Lab Sample ID: **420-111024-68**

Date Sampled: 09/28/2016 0645
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2044	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	3.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L69 Faculty men's room near Rm 206, left sink**
Lab Sample ID: **420-111024-69**

Date Sampled: 09/28/2016 0647
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2046	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	4.2	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L70 Faculty men's room near Rm 206, right sink**
Lab Sample ID: **420-111024-70**

Date Sampled: 09/28/2016 0648
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2048	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L71 Fac. Women's room near Rm 206, left sink**
Lab Sample ID: **420-111024-71**

Date Sampled: 09/28/2016 0648
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2050	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	4.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L72 Room 207Sink Faucet**
Lab Sample ID: **420-111024-72**

Date Sampled: 09/28/2016 0649
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2052	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	13	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L73 Room 207 water fountain**
Lab Sample ID: **420-111024-73**

Date Sampled: 09/28/2016 0649
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 2054	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L74 Room 209 Sink Faucet**
Lab Sample ID: **420-111024-74**

Date Sampled: 09/28/2016 0651
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/25/2016 2102	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	16	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L75 Room 209 water fountain**
Lab Sample ID: **420-111024-75**

Date Sampled: 09/28/2016 0651
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2107	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	5.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L76 Room 210 Sink Faucet**
Lab Sample ID: **420-111024-76**

Date Sampled: 09/28/2016 0652
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2109	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	9.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L77 Room 210 water fountain**
Lab Sample ID: **420-111024-77**

Date Sampled: 09/28/2016 0652
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 1004	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	2.5	ug/L	2.0	2.0	2.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L78 Room 211 Sink Faucet**
Lab Sample ID: **420-111024-78**

Date Sampled: 09/28/2016 0654
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2113	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	9.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L79 Room 211 water fountain**
Lab Sample ID: **420-111024-79**

Date Sampled: 09/28/2016 0654
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/25/2016 2115	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	1.7	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L80 Room 208 left Sink Faucet**
Lab Sample ID: **420-111024-80**

Date Sampled: 09/28/2016 0656
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0934	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	1.1	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L81 Rom 208 right Sink Faucet**
Lab Sample ID: **420-111024-81**

Date Sampled: 09/28/2016 0656
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0934	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	2.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L82 lower water fountain by Room 212**
Lab Sample ID: **420-111024-82**

Date Sampled: 09/28/2016 0658
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0935	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L83 upper water fountain by Room 212**
Lab Sample ID: **420-111024-83**

Date Sampled: 09/28/2016 0658
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/26/2016 0936	
Prep Method: 200				Date Prepared:	10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L84 Library Sink Faucet**
Lab Sample ID: **420-111024-84**

Date Sampled: 09/28/2016 0659
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0937	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L85 Room 216 far left Sink Faucet**
Lab Sample ID: **420-111024-85**

Date Sampled: 09/28/2016 0702
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0937	
Prep Method: 200			Date Prepared:		10/25/2016 1530	
Pb	19	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L86 Room 216 corner right Sink Faucet**
Lab Sample ID: **420-111024-86**

Date Sampled: 09/28/2016 0702
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/26/2016 0938	
Prep Method: 200				Date Prepared:	10/25/2016 1530	
Pb	18	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L87 Room 216 far right Sink Faucet**
Lab Sample ID: **420-111024-87**

Date Sampled: 09/28/2016 0703
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0939	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L88 Rom 216 left Sink Faucet under tarpon**
Lab Sample ID: **420-111024-88**

Date Sampled: 09/28/2016 0704
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/26/2016 0940	
Prep Method: 200				Date Prepared:	10/25/2016 1530	
Pb	22	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L89 Room 216 right Sink Faucet under tarpon**
Lab Sample ID: **420-111024-89**

Date Sampled: 09/28/2016 0704
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0941	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L90 Room 215 Sink Faucet**
Lab Sample ID: **420-111024-90**

Date Sampled: 09/28/2016 0705
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0943	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	12	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L91 Rom 215 water fountain**
Lab Sample ID: **420-111024-91**

Date Sampled: 09/28/2016 0706
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0944	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	1.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L92 Room 217 Sink Faucet**
Lab Sample ID: **420-111024-92**

Date Sampled: 09/28/2016 0707
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0944	
Prep Method: 200		Date Prepared:		10/25/2016 1530	
Pb	15	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L93 Room 217 water fountain**
Lab Sample ID: **420-111024-93**

Date Sampled: 09/28/2016 0707
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0945	
Prep Method: 200			Date Prepared:		10/25/2016 1600	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L94 Room 218 Sink Faucet**
Lab Sample ID: **420-111024-94**

Date Sampled: 09/28/2016 0708
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0948	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	9.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L95 Room 218 water fountain**
Lab Sample ID: **420-111024-95**

Date Sampled: 09/28/2016 0708
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0949	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	3.4	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L96 Room 219 Sink Faucet**
Lab Sample ID: **420-111024-96**

Date Sampled: 09/28/2016 0710
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	10/26/2016 0950	
Prep Method: 200				Date Prepared:	10/25/2016 1600	
Pb	18	g	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L97 Room 219 water fountain**
Lab Sample ID: **420-111024-97**

Date Sampled: 09/28/2016 0710
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0952	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	1.8	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L98 Room 222 Sink Faucet**
Lab Sample ID: **420-111024-98**

Date Sampled: 09/28/2016 0712
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0953	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	14	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L99 Room 222 Water fountain**
Lab Sample ID: **420-111024-99**

Date Sampled: 09/28/2016 0712
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0954	
Prep Method: 200			Date Prepared:		10/25/2016 1600	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L100 Room 221 Sink Faucet**
Lab Sample ID: **420-111024-100**

Date Sampled: 09/28/2016 0713
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0954	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	9.6	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L101 Room 221 water fountain**
Lab Sample ID: **420-111024-101**

Date Sampled: 09/28/2016 0713
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0955	
Prep Method: 200			Date Prepared:		10/25/2016 1600	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L102 Room 224 Sink Faucet**
Lab Sample ID: **420-111024-102**

Date Sampled: 09/28/2016 0715
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0956	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	5.3	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L103 Room 224 water fountain**
Lab Sample ID: **420-111024-103**

Date Sampled: 09/28/2016 0715
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0957	
Prep Method: 200			Date Prepared:		10/25/2016 1600	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L104 Room 223 Sink Faucet**
Lab Sample ID: **420-111024-104**

Date Sampled: 09/28/2016 0716
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0957	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	8.9	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L105 Room 223 water fountain**
Lab Sample ID: **420-111024-105**

Date Sampled: 09/28/2016 0716
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:		10/26/2016 0958	
Prep Method: 200			Date Prepared:		10/25/2016 1600	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L106 Room 226 Sink Faucet**
Lab Sample ID: **420-111024-106**

Date Sampled: 09/28/2016 0718
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 0959	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	6.5	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L107 Room 226 water fountain**
Lab Sample ID: **420-111024-107**

Date Sampled: 09/28/2016 0718
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 1001	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	1.0	ug/L	1.0	1.0	1.0

Michael O'Rourke
Ulster BOCES
175 Roue 32 North
New Paltz, NY 12561

Job Number: 420-111024-1
Sdg Number: New Paltz CSD Lenape

Client Sample ID: **L108Room 225 Sink Faucet**
Lab Sample ID: **420-111024-108**

Date Sampled: 09/28/2016 0720
Date Received: 09/29/2016 1025
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4		Date Analyzed:		10/26/2016 1002	
Prep Method: 200		Date Prepared:		10/25/2016 1600	
Pb	12	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: New Paltz CSD Lenape

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Silicon, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Phenolphthalein Alkalinity, Solids (Fixed), Solids (Percent), Solids (Percent Moisture) , Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), Total Inorganic Carbon, Volatile Acids as Acetic Acid, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, Iron Bacteria, Salmonella, & Sulfur Reducing Bacteria.

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Cobalt (200.7, 200.8), Tin (200.7), Strontium (200.7), Gold (200.7), Platinum (200.7), Palladium (200.7), Titanium (200.7), Phosphorus (365.3), Nitrate-Nitrite (10-107-4-1C, 353.2), m-Xylene & p-Xylene (502.2, 524), Naphthalene (502.2), o-Xylene (502.2, 524), & Fecal Coliform (9222D).

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), & MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: New Paltz CSD Lenape

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY 111024

REPORT# (Lab Use Only)

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE	PROJECT NO.	PROJECT LOCATION
New Paltz CSD Lenape		Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

PAGE 1 of 1

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS: 1

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	REQUIRED ANALYSES: Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
			NUMBER OF CONTAINERS SUBMITTED															
9/28/2016	6:39	L01, Kitchen 2 bay sink left faucet						1			1							Lead (DW 200.8)
9/28/2016	6:40	L02, Kitchen 2 bay sink right faucet						1			1							Lead (DW 200.8)
9/28/2016	6:42	L03, Kitchen center sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:46	L04, Kitchen handwashing sink						1			1							Lead (DW 200.8)
9/28/2016	6:46	L05, Kitchen coffee pot sink						1			1							Lead (DW 200.8)
9/28/2016	6:48	L06, Room 115 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:49	L07, Room 116A sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:51	L08, Room 119 TR sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:52	L09, Room 119 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:52	L10, Room 118 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:54	L11, Room 121 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:54	L12, Room 121 TR sink faucet						1			1							Lead (DW 200.8)
9/28/2016	6:58	L13, Cafeteria water fountain						1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chandler	Ulster BOCES	9/29/16	10:25am				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chandler	Ulster BOCES	9/29/16	10:25am				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

IR #3

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:
[illegible]	9/29/16	1025	YES / NO	21.1	ICE (Y___N___) pH____ CL2____ Reveiwed by____

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

PAGE 2 of 9 | 1

PROJECT REFERENCE	New Paltz CSD Lenape
PROJECT NO.	
PROJECT LOCATION	Lenape
ENVIROTEST PROJECT MANAGER	Debra Bayer
P.O. NUMBER	
TOWN	New Paltz
CLIENT (SITE) PM	results to: morourke@ulsterboces.org
CLIENT PHONE	845-256-4000
CLIENT FAX	
CLIENT NAME	New Paltz CSD
CLIENT ADDRESS	196 Main Street, New Paltz, NY 12561
COMPANY CONTRACTING THIS WORK (if applicable):	

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES

NUMBER OF CONTAINERS SUBMITTED

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/28/2016	7:01	L14, Boy's room by Gym left sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:02	L15, Boy's room by Gym 2nd to left sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:02	L16, Boy's Rm by Gym 2nd from right sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:02	L17, Boy's room by Gym right sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:03	L18, WF by Gym, lower left fountain	1			1							Lead (DW 200.8)
9/28/2016	7:03	L19, WF by Gym, upper left fountain	1			1							Lead (DW 200.8)
9/28/2016	7:04	L20, WF by Gym lower right fountain	1			1							Lead (DW 200.8)
9/28/2016	7:04	L21, WF by Gym upper right fountain	1			1							Lead (DW 200.8)
9/28/2016	7:05	L22, Girl's room by Gym left sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:06	L23, Girl's room by Gym 2nd sink from right faucet	1			1							Lead (DW 200.8)
9/28/2016	7:06	L24, Girl's room by Gym right sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:10	L25, Room 101 sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:10	L26, Room 101 water fountain	1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) Brian Chandler	COMPANY Ulster BOCES	DATE 9/29/16	TIME 10:25am	RECEIVED BY: (SIGNATURE)	COMPA DATE	TIME
SAMPLED BY: (SIGNATURE) Brian Chandler	COMPANY Ulster BOCES	DATE 9/29/16	TIME 10:25am	RECEIVED BY: (SIGNATURE)	COMPA DATE	TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS:
[signature]	9/29/16	1025		21.1 IR#3	ICE (Y___N ✓) pH____ CL2____ Reveiwed by_____

10/31/2016

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

PAGE 3 of 9 | 1

PROJECT REFERENCE: New Paltz CSD Lenape	PROJECT NO.	PROJECT LOCATION: Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES / NUMBER OF CONTAINERS SUBMITTED

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/28/2016	7:12	L27, Room 103 sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:12	L28, Room 103 water fountain	1			1							Lead (DW 200.8)
9/28/2016	7:14	L29, Room 124 left sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:15	L30, Room 102 left sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:15	L31, Room 102 right sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:15	L32, Room 124 right sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:15	L33, Room 124 TR sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:16	L34, Room 102 water fountain	1			1							Lead (DW 200.8)
9/28/2016	7:16	L35, Room 102 TR sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:20	L36, Room 104 left sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:20	L37, Room 104 right sink faucet	1			1							Lead (DW 200.8)
9/28/2016	7:20	L38, Room 104 water fountain	1			1							Lead (DW 200.8)
9/28/2016	7:21	L39, Room 104 TR sink faucet	1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chandler	Ulster BOCES	9/29/16	10:25am				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chandler	Ulster BOCES	9/29/16	10:25am				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:
[signature]	9/29/16	1025	YES / NO	21.1 IR#3	ICE (Y___N✓) pH____ CL2____ Reveiwed by_____

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

REPORT# (Lab Use Only)

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PAGE 4 of 9 | 1

PROJECT REFERENCE: New Paltz CSD Lenape	PROJECT NO.	PROJECT LOCATION: Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE; AQUEOUS (WATER); D (Drinking Water) or W (Waste Water) Indicate; SOLID OR SEMISOLID; OTHER Specify

REQUIRED ANALYSES / NUMBER OF CONTAINERS SUBMITTED

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/28/2016	7:22	L40, Room 105 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:22	L41, Room 105 water fountain						1			1							Lead (DW 200.8)
9/28/2016	7:23	L42, Room 107 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:24	L43, Room 107 water fountain						1			1							Lead (DW 200.8)
9/28/2016	7:25	L44, Room 109 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:25	L45, Room 109 water fountain						1			1							Lead (DW 200.8)
9/28/2016	7:26	L46, Room 110 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:26	L47, Room 110 water fountain						1			1							Lead (DW 200.8)
9/28/2016	7:27	L48, Room 111 sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:27	L49, Room 111 water fountain						1			1							Lead (DW 200.8)
9/28/2016	7:29	L50, Nurse's office sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:29	L51, Nurse's office TR sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:31	L52, Women's room by Main Office left sink faucet						1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chamber	Ulster BOCES	9/29/16	10:25 am				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chamber	Ulster BOCES	9/29/16	10:25 am				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS: ICE (Y___N___) pH____ CL2____ Reveiwed by_____
[signature]	9/29/16	1025		21.1 IR#3	

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

REPORT# (Lab Use Only)

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE	PROJECT NO.	PROJECT LOCATION
New Paltz CSD Lenape		Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

PAGE 5 of 7 | 1

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/28/2016	7:31	L53, Women's Rm by Main Office right sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:32	L54, water fountain outside Main Office						1			1							Lead (DW 200.8)
9/28/2016	7:33	L55, Men's room by Main Office left sink faucet						1			1							Lead (DW 200.8)
9/28/2016	7:33	L56, Men's room by Main Office right sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:38	L57, Room 201 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:38	L58, Room 201 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:39	L59, Room 202 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:39	L60, Room 202 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:40	L61, Room 203 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:40	L62, Room 203 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:42	L63, Room 204 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:42	L64, Room 204 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:43	L65, Room 205 sink faucet						1			1							Lead (DW 200.8)

NUMBER OF CONTAINERS SUBMITTED

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chandler	Ulster BOCES	9/29/16	10:25 am				
SAMPLED BY: (SIGNATURE) Brian Chandler	COMPANY Ulster BOCES	DATE 9/29/16	TIME 10:25 am	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS:
R Moore	9/29/16	1025		21.1	ICE (Y___N___) pH____ CL2____ Reveiwed by_____

IR#3

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

REPORT# (Lab Use Only)

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

PROJECT REFERENCE: New Paltz CSD Lenape
PROJECT NO.:
PROJECT LOCATION: Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer
P.O. NUMBER:
TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org
CLIENT PHONE: 845-256-4000
CLIENT FAX:
CLIENT NAME: New Paltz CSD
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561
COMPANY CONTRACTING THIS WORK (if applicable):

PAGE 6 of 7

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS: 1

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/29/2016	6:43	L66, Room 205 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:45	L67, Room 206 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:45	L68, Room 206 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:47	L69, Faculty Men's room near Rm 206, left sink						1			1							Lead (DW 200.8)
9/29/2016	6:48	L70, Faculty Men's room near Rm 206, right sink						1			1							Lead (DW 200.8)
9/29/2016	6:48	L71, Fac. Women's room near Rm 206, left sink						1			1							Lead (DW 200.8)
9/29/2016	6:49	L72, Room 207 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:49	L73, Room 207 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:51	L74, Room 209 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:51	L75, Room 209 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:52	L76, Room 210 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:52	L77, Room 210 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:54	L78, Room 211 sink faucet						1			1							Lead (DW 200.8)

NUMBER OF CONTAINERS SUBMITTED

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chamberlain	Ulster BOCES	9/29/16	10:25 am				
SAMPLED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chamberlain	Ulster BOCES	9/29/16	10:25 am				
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS:
[signature]	9/29/16	1025		24.1	ICE (Y___N___) pH____ CL2____ Reveiwed by_____

IR#3

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

PROJECT REFERENCE	PROJECT NO.	PROJECT LOCATION
New Paltz CSD Lenape		Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

PAGE 7 of 9 | 1

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	REQUIRED ANALYSES: Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/29/2016	6:54	L79, Room 211 water fountain						1			1							Lead (DW 200.8)
9/29/2016	6:56	L80, Room 208 left sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:56	L81, Room 208 right sink faucet						1			1							Lead (DW 200.8)
9/29/2016	6:58	L82, lower water fountain by Room 212						1			1							Lead (DW 200.8)
9/29/2016	6:58	L83, upper water fountain by Room 212						1			1							Lead (DW 200.8)
9/29/2016	6:59	L84, Library sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:02	L85, Room 216 far left sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:02	L86, Room 216 corner right sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:03	L87, Room 216 far right sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:04	L88, Room 216 left sink faucet under tarpon						1			1							Lead (DW 200.8)
9/29/2016	7:04	L89, Room 216 right sink faucet under tarpon						1			1							Lead (DW 200.8)
9/29/2016	7:05	L90, Room 215 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:06	L91, Room 215 water fountain						1			1							Lead (DW 200.8)

NUMBER OF CONTAINERS SUBMITTED

RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
Brian Chandler	Ulster BOCES	9/29/16	10:25am				
SAMPLED BY: (SIGNATURE) Brian Chandler	COMPANY Ulster BOCES	DATE 9/29/16	TIME 10:25am	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT	Cooler Temp(C):	LABORATORY REMARKS:
[signature]	9/29/16	1025	YES / NO	21.1 (IR#3)	ICE (Y___N___) pH____ CL2____ Reveiwed by____

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY

111024

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

PROJECT REFERENCE: New Paltz CSD Lenape	PROJECT NO.	PROJECT LOCATION: Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer	P.O. NUMBER	TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org	CLIENT PHONE: 845-256-4000	CLIENT FAX
CLIENT NAME: New Paltz CSD		
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561		
COMPANY CONTRACTING THIS WORK (if applicable):		

PAGE 8 of 9 1

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	REQUIRED ANALYSES: Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
9/29/2016	7:07	L92, Room 217 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:07	L93, Room 217 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:08	L94, Room 218 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:08	L95, Room 218 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:10	L96, Room 219 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:10	L97, Room 219 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:12	L98, Room 222 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:12	L99, Room 222 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:13	L100, Room 221 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:13	L101, Room 221 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:15	L102, Room 224 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:15	L103, Room 224 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:16	L104, Room 223 sink faucet						1			1							Lead (DW 200.8)

NUMBER OF CONTAINERS SUBMITTED

	COMPANY	DATE	TIME		COMPA	DATE	TIME
RELINQUISHED BY: (SIGNATURE) Brian Glandon	Ulster BOCES	9/29/16	10:25am	RECEIVED BY: (SIGNATURE)			
SAMPLED BY: (SIGNATURE) Brian Glandon	Ulster BOCES	9/29/16	10:25am	RECEIVED BY: (SIGNATURE)			
RELINQUISHED BY: (SIGNATURE)				RECEIVED BY: (SIGNATURE)			

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C):	LABORATORY REMARKS: ICE (Y__N__) pH____ CL2____ Reveiwed by____
[signature]	9/29/16	1025		21.1	

EnviroTest Laboratories, Inc.

CHAIN OF CUSTODY 111024

Lab Name: EnviroTest Laboratories
Address & Phone: 315 Fullerton Avenue, Newburgh, New York 12550 845-562-0890

REPORT# (Lab Use Only)

PROJECT REFERENCE: New Paltz CSD Lenape
PROJECT NO.:
PROJECT LOCATION: Lenape
ENVIROTEST PROJECT MANAGER: Debra Bayer
P.O. NUMBER:
TOWN: New Paltz
CLIENT (SITE) PM: results to: morourke@ulsterboces.org
CLIENT PHONE: 845-256-4000
CLIENT FAX:
CLIENT NAME: New Paltz CSD
CLIENT ADDRESS: 196 Main Street, New Paltz, NY 12561
COMPANY CONTRACTING THIS WORK (if applicable):

PAGE 9 of 9 | 1

TURNAROUND TIME: NORMAL ____ QUICK ____ VERBAL ____

#OF COOLERS

SAMPLE DATE	SAMPLE TIME	SAMPLE IDENTIFICATION	MATRIX TYPE: COMPOSITE (C) OR GRAB (G) INDICATE	AQUEOUS (WATER)	D (Drinking Water) or W (Waste Water) Indicate	SOLID OR SEMISOLID	OTHER Specify	REQUIRED ANALYSES: Total # of Containers	40ml Vials HCl	Liter Amber HCl	250ml Plastic Nitric Acid	250ml Plastic Sulfuric Acid	Liter Plastic	250ml Plastic	Terra Core	Other	Other	REMARKS
								NUMBER OF CONTAINERS SUBMITTED										
9/29/2016	7:16	L105, Room 223 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:18	L106, Room 226 sink faucet						1			1							Lead (DW 200.8)
9/29/2016	7:18	L107, Room 226 water fountain						1			1							Lead (DW 200.8)
9/29/2016	7:20	L108, Room 225 sink faucet						1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)
9/29/2016								1			1							Lead (DW 200.8)

RELINQUISHED BY: (SIGNATURE) Brian Chamberlin	COMPANY Ulster BOCES	DATE 9/29/16	TIME 10:25am	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
SAMPLED BY: (SIGNATURE) Brian Chamberlin	COMPANY Ulster BOCES	DATE 9/29/16	TIME 10:25 am	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME
RELINQUISHED BY: (SIGNATURE)	COMPANY	DATE	TIME	RECEIVED BY: (SIGNATURE)	COMPA	DATE	TIME

RECEIVED FOR LABORATORY BY: (SIGNATURE)	DATE	TIME	CUSTODY INTACT YES NO	Cooler Temp(C): 2.1	LABORATORY REMARKS: ICE (Y___N___) pH____ CL2____ Reveiwed by____
	9/29/16	1095			

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-111024-1
SDG Number: New Paltz CSD Lenape

Login Number: **111024**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	21.1 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

APPENDIX B

Caution Signage

CAUTION: NONPOTABLE WATER – DO NOT DRINK

CAUTION: NONPOTABLE WATER – DO NOT DRINK

CAUTION

NON-POTABLE
WATER
DO NOT DRINK